



Certificate of Compliance

Certificate: 2235013

Master Contract: 189705

Project: 80073256

Date Issued: 2021-03-11

Issued To: Socomec S.A.
rue de Westhouse 1
BP 10
Benfeld Cedex, Bas-Rhin, 67235
France

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Steven Montminy*
Steven Montminy



PRODUCTS

CLASS - C465102 - SWITCHES Dead-front (Open Type)

Part A

Open Type Switches, Manual, Designate: Fuserbloc J30 and Fuserbloc J60, single contact, 2 to 4 poles. Cat. Nos. 38512004, 38512005, 38513004, 38513005, 38516004, 38516005, 38612004, 38612005, 38613004, 38613005, 38616004, 38616005, 37172004, 37172005, 37173004, 37173005, 37176004 and 37176005. Rating: Fuserbloc J30: General use: 30A, 600Vac max, 25HP max. 250Vdc max, 5HP max., 200kA at 600Vac, and 10AWG and 100kA, 250V dc, copper only; Fuserbloc J60: General use: 60A, 600Vac, 50HP max, 250Vdc max., 10 HP max, 100kA, 600Vac, and 100kA, 250V dc, 6AWG copper only.

Part B

Open Type Switches, Manual, Designate: Fuserbloc J60 and Fuserbloc J100, double contact, 2 to 4 poles Cat. Nos. 38512006, 38512010, 38513006, 38513010, 38516006, 38516010, 38612006, 38612010, 38613006, 38613010, 38616006, 38616010, 37172006, 37172010, 37173006, 37173010, 37176006 and 37176010. Rating: Fuserbloc J60: General use: 60A 600Vac max, 50HP max. 250Vdc max, 10HP max., 200kA at 600Vac, and



Certificate: 2235013
Project: 80073256

Master Contract: 189705
Date Issued: 2021-03-11

100kA, 250V ac, 10 AWG to 2/0 AWG copper wires only; Fuserbloc J100: General use: 100A, 600Vac, 75HP max, 250Vdc max., 20 HP max, 200kA, 600Vac, and 100kA, 250V dc, 10 AWG to 2/0 AWG copper wires only.

Part C

Adaptation kits for flange handle, Cat. No. 39299992, 39299993 & 39299994 to be used with Rockwell handles Cat. No. 1494F-P1, 1494F-M1 and 1494F-S1 or fused switches series Fuserbloc J100, cat. No. 38613010.

APPLICABLE REQUIREMENTS

- CSA C22.2 No. 0-10 - General Requirements – Canadian Electrical Code Part II
- CSA-C22.2 No. 4-16 - Enclosed Switches – Eighth Edition with update 1 – Dated August 2019



Supplement to Certificate of Compliance

Certificate: 2235013

Master Contract: 189705

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80073256	2021-03-11	Updates of report 189705-2235013 to cover addition of alternate plastic material manufactured by Domo Polytechnyl Sas to the component “cam” (item 8) of switching module (part A and B), in accordance with the standard CSA C22.2 No.4-16 with update 1 as per certification notice no. 24.
000070107193	2017-09-12	Update report as per Notice 21 (CSA C22.2 No.4-16).
000070089914	2016-08-18	Modification of wire gauge and torque.
000070050804	2015-11-19	Modification of the plastic manufacturer.
0002753089	2014-08-19	Addition of Adaptation kit for flange handle, Cat. No. 39299992, 39299993 & 39299994.
0002676045	2014-01-13	Modification of short-circuit rating of 250Vdc at 100kA.
0002529482	2012-07-12	Addition of optional auxiliary holder, operating peg, handle cat no. 194R-HM4—N2-L and auxiliary contact cat nos 800x10, 800x01 by Rockwell into cat no. Fuserbloc J100.
0002478890	2011-12-07	Clarification of terminal clamp description
0002235013	2009-11-27	New certification of Fuse switch model FUSERBLOC J30, J60 and J100