

IEC**IECEE**

®

™

Ref. Certif. No.

CN59622

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S
1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCOMECS ELECTRIC (SHANGHAI) CO.,LTD
Building A30, No.5399 Waiqingsong Road Qing Pu.Shanghai
P.R.China

Additional information on page 2

Ratings and principal characteristics

See the Appendix

Trademark / Brand (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS 125A, ATyS d 125A, ATyS t 125A, ATyS g 125A, ATyS p 125A, ATyS A 125A,
ATyS C 125A, ATyS 160A, ATyS d 160A, ATyS t 160A, ATyS g 160A, ATyS p
160A, ATyS A 160A, ATyS C 160A, ATyS 200A, ATyS d 200A, ATyS t 200A,
ATyS g 200A, ATyS p 200A, ATyS A 200A, ATyS C 200A

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2005 (2nd Edition) + AMD 1:2013 for use in
conjunction with IEC 60947-1:2007 (5th Edition) + AMD 1:2010

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2022CQC-103450

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Jun.06,2023

Signature:

Xie ZhaoXu

CB 0073736

ATyS 125A, ATyS d 125A, ATyS t 125A, ATyS g 125A, ATyS p 125A, ATyS A 125A, ATyS C 125A,
ATyS 160A, ATyS d 160A, ATyS t 160A, ATyS g 160A, ATyS p 160A, ATyS A 160A, ATyS C 160A,
ATyS 200A, ATyS d 200A, ATyS t 200A, ATyS g 200A, ATyS p 200A, ATyS A 200A, ATyS C 200A

Ui: 800V(Main circuit), 300V(Control circuit);

Uimp: 8kV(Main circuit), 4kV(Control circuit);

Ue: AC415V;

ATyS 125A, ATyS d 125A, ATyS t 125A, ATyS g 125A, ATyS p 125A, ATyS A 125A, ATyS C 125A:

Ith:125A; Ie: 125A; Iq: 100kA;

ATyS 160A, ATyS d 160A, ATyS t 160A, ATyS g 160A, ATyS p 160A, ATyS A 160A, ATyS C 160A:

Ith: 160A; Ie: 160A; Iq: 100kA;

ATyS 200A, ATyS d 200A, ATyS t 200A, ATyS g 200A, ATyS p 200A, ATyS A 200A, ATyS C 200A:

Ith: 200A; Ie: 200A; Iq: 50kA;

Utilization Category: AC-31B;

Icm(Peak):17kA;Icw: 10kA(30ms);

ATSE,RTSE;

PC;

3P, 4P

Additional information (if necessary)

Date: Jun.06,2023

Signature:

谢肇煦

Xie ZhaoXu

IEC**IECEE**

®

TM

Ref. Certif. No.


CN59622

Name of the factory	Address of the factory
SOCOMEK S.A.S	1, Rue De Westhouse 67230 Benfeld Cedex France
SOCIETE TIMELEC SARL	ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS, Tunisia

Additional information (if necessary)

Date: Jun.06,2023

Signature:



Xie ZhaoXu