

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2016010302839975

Valid from: Mar.16,2021

Valid until: Feb.04,2031

NAME AND REGISTERED ADDRESS OF THE APPLICANT SOCOMEC China Co.,Ltd.
Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

PRODUCT NAME, MODEL AND SPECIFICATION Fuse-switch-disconnector
Model: FUSERBLOC 250A, FUSERBLOC 400A;Uimp:8kV;Ui:800V;Ith: 250A,400A;Ue): AC415V(FUSERBLOC 400A), AC690V(FUSERBLOC 250A, FUSERBLOC 400A);Ie: 250A,400A;Iq:50kA;Utilization Category: AC-22B(仅 FUSERBLOC 400A),AC-23A;Poles: 2P,3P,4P , 3P+Additional neutral pole(N) (Uninterrupted N Pole);Frequency of operating cycles:50/60Hz

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.3-2017

TYPE OF CERTIFICATION SCHEMES Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.
The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

PRESIDENT:

CHINA QUALITY CERTIFICATION CENTRE