

PRODUCT CERTIFICATION

TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2015010305775627

Valid from: Mar.16,2021

Valid until: Apr.17,2022

NAME AND REGISTERED ADDRESS OF THE APPLICANT SOCOMEC China Co.,Ltd.
Unit k, 6/F, No.258 , Fute North Road, Pilot Free Trade Zone Shanghai, P.R.China

NAME AND REGISTERED ADDRESS OF THE MANUFACTURER SOCOMEC S.A
1, Rue De Westhouse 67230 Benfeld Cedex France

NAME AND LOCATION OF THE FACTORY Wuxi Elecube Co.,Ltd.
No.555 Xida Road, Meicun, National High-tech Industrial Development Zone, Wuxi

PRODUCT NAME, MODEL AND SPECIFICATION Tranfer Switching Equipment
ATys dH 4000A, ATys dH 5000A, ATys dH 6300A; Ui : 1000V; Uimp(Main Circuit) : 12kV; Uimp (Control Circuit) : 4kV ; Ith : 6300A; Ue : AC660V; Ie : 4000A, 5000A, 6300A; Utilization Category :AC-33iB; Icm(Peak Value) :143kA; Icw :65kA/0.1s; ATSE Class :PC ;Transfer Mode : RTSE; Poles : 3P,4P;

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS GB/T 14048.11-2016

TYPE OF CERTIFICATION SCHEMES modeNameEn

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: www.cnca.gov.cn



SIGNED BY:

徐军

PRESIDENT:

陆楠

CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0014360

产品认证证书

II型自愿认证

证书编号: CQC2015010305775627

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 14360

ATys dH 4000A, ATys dH 5000A, ATys dH 6300A

额定绝缘电压(U_i): 1000V;

额定冲击耐受电压(U_{imp}): 12kV;

控制回路额定冲击耐受电压(U_{imp}): 4kV;

约定发热电流(I_{th}): 6300A;

额定工作电压(U_e): AC660V;

额定工作电流(I_e): 4000A、5000A、6300A;

使用类别: AC-33iB;

额定短路接通能力(I_{cm})(峰值): 143kA;

额定短时耐受电流(I_{cw}): 65kA/0.1s;

电器级别: PC 级;

转换方式: RTSE;

极数: 3P, 4P.

型号的解释:

附件



中国质量认证中心

产品认证证书

II型自愿认证

证书编号: CQC2015010305775627

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 14360

<u>ATys</u>	<u>d</u>	<u>H</u>	<u>□</u>
(1)	(2)	(3)	(4)

- (1) ATys: 转换开关系列
 - (2) d: 双电源供电
 - (3) H: 大电流
 - (4) 额定工作电流: 4000A, 5000A, 6300A
- 注: 产品安装方式有两种: 固定式, 抽出式。

附件



中国质量认证中心