

IEC

IECEE



TM

Ref. Certif. No.

CN65937

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the manufacturer

SOCOMECS.A.S

1, Rue De Westhouse 67230 Benfeld Cedex France

Name and address of the factory

Note: When more than one factory, please report on page 2

SOCIETE TIMELEC SARL

ZONE INDUSTRIELLE CHEBEDA ROUTE DE FOUCHANA
NAASSEN 1135 NAASSEN GOUVERNORATDE BEN AROUS,
Tunisia

Ratings and principal characteristics

Ui:1000V; Uimp:12kV; Ith: 500A,630A; Ue:AC415V; Ie: SIRCOVER
AC 500A: 500A(AC-32B),400A(AC-33B); SIRCOVER AC 630A:
630A(AC-31B),500A(AC-32B),400A(AC-33B); Utilization
category:AC-33B,AC-32B,AC-31B; Iq:50kA; Class of equipment: PC;
Method of controlling: MTSE; Number of poles: 3P,4P

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SIRCOVER AC 500A, SIRCOVER AC 630A;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-6-1:2021;IEC 60947-1:2020

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2024CQC-113618

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: May.29,2024

Signature:

谢肇煦

Xie ZhaoXu

