

IEC**IECEE**

Ref. Certif. No.

CN76372

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Transfer Switching Equipment

Name and address of the applicant

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

Name and address of the manufacturer

SOCOMECS.A.S
1, RUE DE WESTHOUSE 67230 BENFELD CEDEX FRANCE

Name and address of the factory

Hangzhou Socomec Co.,Ltd.
2nd Floor, Building 2, No. 118, Songqiao Street, Xiasha Sub-district,
Qiantang District, Hangzhou City, Zhejiang Province*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Ui:800V(main circuit);450V(control circuit,auxiliary circuit);
Uimp:6kV(main circuit,control circuit,auxiliary circuit);
Ue:AC415V;50/60Hz; Ith=Ie:80A,100A,125A,160A; Utilization
category:AC-33B; Icw:10kA/60ms;Icm(peak):17kA; Iq:50kA;
Class of equipment:PC; ATSE; 4P.

Trademark (if any)

SOCOMECS

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

ATyS a M 80A,ATyS a M 100A,ATyS a M 125A,ATyS a M 160A

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-6-1:2021; IEC 60947-1:2020

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2026CQC-126871

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.Section 9, No. 188, Nansihuan Xilu, Fengtai District, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Mar.17,2026

Signature:

Liu Jiang